

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Original Certificate

Certificate Reference Number **MK07062026/01**

DETAILS OF CLIENT/LANDLORD

Client/
Address: DJ Cloud - Herts.

TEST EQUIPMENT DETAILS

Test Equipment used MEGGER PAT3

Serial Number MP50003783

Tested by C.Clarkson

Date 07/06/26

Retest Date 06/06/27

Serial No:	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?
01	Mackie 12a Active Speaker	VENUE	240	1300W	13	>20MΩ	0.6	OK	YES
02	Mackie 12a Active Speaker	VENUE	240	1400W	13	>20MΩ	0.6	OK	YES
03	Beamz MHL 74 Moving Head LED	VENUE	240	70W	13	>20MΩ	0.6	OK	YES
04	Beamz MHL 74 Moving Head LED	VENUE	240	70W	13	>20MΩ	0.6	OK	YES
05	Starcloth Blue LED	VENUE	240	30W	13	>20MΩ	0.6	OK	YES
06	Starcloth Multi Colour LED	VENUE	240	30W	13	>20MΩ	0.6	OK	YES
07	Starcloth White LED	VENUE	240	30W	13	>20MΩ	0.6	OK	YES
08	Beamz 4Some LED	VENUE	240	50W	13	>20MΩ	0.6	OK	YES
09	ADJ VMS5 Controller + Adaptor	VENUE	240	50/60HZ	13	>20MΩ	0.6	OK	YES
10	QTX Gala 9 LED Light	VENUE	240	10w	13	>20MΩ	0.6	OK	YES
11	Par Cam 56 LED Light	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
12	Par Cam 56 LED Light	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
13	Par Cam 56 LED Light	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
14	Par Cam 56 LED Light	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
15	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
16	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
17	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
18	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
19	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
20	Uplighter LED	VENUE	240	30w	13	>20MΩ	0.6	OK	YES
21	2 Gang Extension Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
22	4 Gang Extension Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
23	4 Gang Extension Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
24	4 Gang Extension Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
25	4 Gang Extension Reel	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
26	2 Gang Extension Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
27	4 Gang Extension Surge Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
28	4 Gang Extension Surge Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
29	HP Pavilion Laptop Power Adaptor	VENUE	240	50/60HZ	3	>20MΩ	0.6	OK	YES
30	Linx Laptop Power Adaptor	VENUE	240	50/60HZ	3	>20MΩ	0.6	OK	YES
31	Numark Wireless Microphone Adaptor	VENUE	240	50/60HZ	3	>20MΩ	0.6	OK	YES
32	IEC Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
33	IEC Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
34	IEC Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
35	IEC Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES
36	IEC Lead	VENUE	240	3000W	13	>20MΩ	0.6	OK	YES

SIGNED - C.Clarkson

DATE - 07/06/2026